



JOYONWAY
BY BALBGA

P68B123

SPA CONTROL SYSTEM

1	220-240V~ 32A 50Hz
2	380-415V 3N~ 22A 50Hz
3	120V~ 32A 60Hz
4	240V~ 32A 60Hz
5	240V~ and 120V~ 32A 60Hz



V1.0

Revised version

Version	Revised content	Revised by	Revision date
V1.0	New revision	Sun Hydraulics (China) co.,Ltd. Dongguan Branch	2024/01/02

Contents

Warning	02~03
1. Product overview	04
2. Product dimensions	
2.1. P68B123 Control System Dimensions and Installation Instruction	05~07
3. Basic Information	
3.1. Wiring diagram	08
3.2. Power supply and load	09~15
3.3. Configure load	
3.3.1. Configuring functions with Dip switch	16~17
3.3.2. Configuring functions with the control panel	18~26
3.3.3. Power configuration of the lamp	27
4. Replaceable parts	27
PB562/PB562 Plus control panel shortcut buttons	28
PB563/PB563 Plus control panel shortcut buttons	29
PB565/PB565 Plus control panel main interface	30



Cautious for electric shock!

Please carefully read the following items before installation or connection.

1. Appliances must be permanently connected to fixed wiring.
2. Parts incorporating electrical components, except remote control devices, must be located or fixed so that they cannot fall into the bath.
3. The appliance must be supplied through a residual current device (RCD/GFCI) having a rated residual operating current not exceeding 30 mA.
4. These devices can be connected only to a supply with system impedance no more than 0.099 ohm for Single-phase input or 0.001 ohm for Multi-phase input. In case necessary, please consult your supply authority for system impedance information.
5. This product is not suitable for cleaning with water or other dissolvant. Please do not attempt to maintain this control system yourself; If the product needs to be maintained, please contact your distributor or repair service agency. Please follow all the instructions on power connection in the manual. Installation must be conducted by a licensed electrician. All ground wire must be properly installed. (Recommended tightening torque for ground wire is 3 N • M)
6. Use only copper conductors with a temperature resistance of more than 75°C for power supply.
7. The European standard single-phase input current cannot exceed 32A. The three-phase input current cannot exceed 22A. The American standard input current cannot exceed 32A; The load current carried by the control system cannot exceed the rated input current.
8. End product can have another the connection of external equipotential bonding conductors.
9. This controller is not intend for transportable pool use.

Correct Disposal of this product



This marking indicates that this product should not be disposed with other household wastes throughout the EU. To prevent possible harm to the environment or human health from uncontrolled waste disposal, recycle it responsibly to promote the sustainable reuse of material resources. To return your used device, please use the return and collection systems or contact the retailer where the product was purchased. They can take this product for environmental safe recycling.

Maintenance Warning

When repairing and replacing the heating wire, professional operation is required, be sure to use JOYON-WAY's certified O-rings to ensure that no O-rings are missed and installed to ensure that the heating tube is sealed and does not leak.

As shown in the following figure:



After repairing and replacing the heating element, install the sealing parts back to place. As shown in the following figure:



1. Product overview

Power input: 220-240V~ 32A 50Hz
380-415V 3N~ 22A 50Hz
120V~ 32A 60Hz
240V~ 32A 60Hz
240V~ and 120V~ 32A 60Hz

Output for one set of ON/OFF type or
RGB type SPA light (+5V/2A or +12/1A)
1 set of single-speed pump (10.5A)
1 set of blower (10.5A)
1 set of circ-pump (3.5A)
1 set of thermostatic heating
(2000W or 3000W or 4000W@230V~)
1 set of ozone (1A)
1 set of auxiliary power output (10.5A)

Model: P68B123





Use of ambient temperature -20°C~55°C

Clock display	Freeze protection	Heating timer	Water circulation timer
Matched panels:	Any version of PB562/PB562 Plus Any version of PB563/PB563 Plus Any version of PB565/PB565 Plus	Heating element:	2KW heating tube 3KW heating tube 4KW heating tube


2. Product dimensions

2.1. P68B123 Control System Dimensions and Installation Instruction




Installation Instruction


Fixed installation




1. Materials and tools to be prepared;



2. The distance between the product and obstacles should be above 20mm



3. Please make holes on the fixing plate according to the dimensions shown in the above figure;



4. As shown in the figure, align the control pack with the fixing plate hole position and use a special wrench to lock in M6 screws in sequence;



5. As shown in the figure: after fixing the base plate of the control pack, place waterproof rubber ring into the joint , and tighten the water pipe joint as required;




6. Tighten the water pipe joint, and complete the control pack installation.

Installation Instruction


P68B123 power cord connection



1. Installation tools.



2. Peel the power cord to approximately the size shown in the figure.



3. ① Firstly, use a screwdriver to poke the waterproof rubber plug and remove the the rubber plug poked;
- ② Loosen the gland nut according to the rotation direction shown in the figure above;
- ③ Unscrew the screw of the "main power input connector" upwards to make the connector wiring port loose.



4. Connect the main power cord from the through hole of the gland nut; Connect the power cord to the corresponding connector hole as shown in the wiring diagram on the control pack cover.



5. After the power cord is connected to the connector hole, tighten the screw with a screwdriver to compress the wire tightly. The recommended torque is 2.5-3.0N · M, and check if the power cord is secure.



6. After confirming that each power cord is securely buckled, tighten the waterproof nut of the power cord, and then use a special wrench to tighten it completely.

Installation Instruction

Wire installation



Error of control system wire connecting, as shown in the above figure



Because the driver may operate in a humid environment, steam may condense into water droplets on the wire of the product due to the large temperature difference and other reasons, or water leakage may occur. The water will flow to the product along wire, and the product may be damaged if soaked for a long time. It is strongly recommended to install the driver according to the following requirements:

All the wires of the control system are bent into a U shape, as shown in the above figure

Installation Instruction

P68B123 Power Cable Specifications

It is recommended to use 3 * 6mm² cable when the total load current is 32A



220 - 240V~ 32A 50Hz
J2 - J3 J4 - J5
J6 - J7

① - L BROWN
② - N BLUE
① - G YE/GN

It is recommended to use 4 * 2.5mm² or 4 * 4mm² power cable when the total load current is 22A



380 - 415V 3N~ 22A 50Hz
J2 - J3 J1 - J7
J4 - J5

① - L2 BLACK
③ - L1 BROWN
② - N BLUE
① - G YE/GN

It is recommended to use a 3 * 10AWG power cable when the total load current is 32A



240V~ 32A 60Hz
J2 - J3 J4 - J5
J6 - J7

③ - L1 BLACK
② - L2 RED
① - G GREEN

It is recommended to use a 4 * 10AWG power cable when the total load current is 32A



240V~ and 120V~ 32A 60Hz
J1 - J3 J4 - J5
J6 - J7

④ - N WHITE
③ - L1 BLACK
② - L2 RED
① - G GREEN

It is recommended to use a 4 * 10AWG power cable when the total load current is 32A



240V~ and 120V~ 32A 60Hz
J2 - J3 J1 - J5
J6 - J7

④ - L2 RED
③ - L1 BLACK
② - N WHITE
① - G GREEN

It is recommended to use a 3 * 10AWG power cable when the total load current is 32A



120V~ 32A 60Hz
J2 - J3 J4 - J5
J6 - J7



③ - L BLACK
② - N WHITE
① - G GREEN

Users choose the appropriate power cable based on the actual load electrical parameters.

For supply connections , Use copper conductors only, Temperature at least 75°C (167°F),

3. Basic information

3.1. Wiring diagram



3.2. Power supply and load


POWER INPUT AND LOAD OUTPUT

PAY ATTENTION TO THE DIFFERENT CONNECTIONS BETWEEN J1/J2/J3/J4/J5/J6/J7 IN EACH POWER TYPE.

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)						
		TB1	CN1	CN3	CN1	CN2	CN4	CN10	J15 J16	CN22
220 - 240V~ 32A 50Hz J2 - J3 J4 - J5 J6 - J7	③ - L BROWN ② - N BLUE ① - G YE/GN	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L-HI / 3-L-LO 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	2-L 1-N	J15-L J16-N	12V ■■■ 1A or 5V ■■■ 2A	
380 - 415V 3N~ 22A 50Hz J2 - J3 J1 - J7 J4 - J5	④ - L2 BLACK ③ - L1 BROWN ② - N BLUE ① - G YE/GN	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1-HI / 3-L1-LO 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-N	J15-L2 J16-N	12V ■■■ 1A or 5V ■■■ 2A	
240V~ 32A 60Hz J2 - J3 J4 - J5 J6 - J7	③ - L1 BLACK ② - L2 RED ① - G GREEN	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1-HI / 3-L1-LO 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	2-L1 1-L2	J15-L1 J16-L2	12V ■■■ 1A or 5V ■■■ 2A	
240V~ and 120V~ 32A 60Hz J1 - J3 J4 - J5 J6 - J7	④ - N WHITE ③ - L1 BLACK ② - L2 RED ① - G GREEN	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-N / 1-G	N/A	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-L2	J15-L1 J16-L2	12V ■■■ 1A or 5V ■■■ 2A	
240V~ and 120V~ 32A 60Hz J2 - J3 J1 - J5 J6 - J7	④ - L2 RED ③ - L1 BLACK ② - N WHITE ① - G GREEN	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G		4-L1-HI / 3-L1-LO 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-N	J15-L1 J16-L2	12V ■■■ 1A or 5V ■■■ 2A	
120V~ 32A 60Hz J2 - J3 J4 - J5 J6 - J7	③ - L BLACK ② - N WHITE ① - G GREEN	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L-HI / 3-L-LO 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	2-L 1-N	J15-L J16-N	12V ■■■ 1A or 5V ■■■ 2A	

220-240V~ 32A 50Hz **J2 - J3 J4 - J5 J6 - J7**

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)						
		TB1	CN1	CN3	CN1					
220 - 240V~ 32A 50Hz J2 - J3 J4 - J5 J6 - J7	③ - L BROWN ② - N BLUE ① - G YE/GN	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L-HI / 3-L-LO 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	2-L 1-N	J15-L J16-N	12V \equiv 1A 5V \equiv 2A	
		220-240V~ 10.5A	220-240V~ 3.5A	220-240V~ 10.5A	220-240V~ 10.5A	220-240V~ 1A	220-240V~ 10.5A	220-240V~		




380-415V 3N~ 22A 50Hz

J2 - J3 J1 - J7 J4 - J5

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)						
		TB1	CN1	CN3	CN1					
380 - 415V 3N~ 22A 50Hz	J2 - J3 J1 - J7 J4 - J5	④ - L2 BLACK ③ - L1 BROWN ② - N BLUE ① - G YE/GN	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1-HI / 3-L1-LO 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-N	J15-L2 J16-N	12V \equiv 1A or 5V \equiv 2A
			220-240V~ 10.5A	220-240V~ 3.5A	220-240V~ 10.5A	220-240V~ 10.5A	220-240V~ 1A	220-240V~ 10.5A	220-240V~	


Load carried by L1 phase: PUMP1 / CIRC PUMP / BLOWER / OZONE / AUX

Load carried by L2 phase: HEATER



240V~ 32A 60Hz J2 - J3 J4 - J5 J6 - J7

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4	BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)						
		TB1	CN1	CN3	CN1	CN2	CN4	CN10	J15 J16
240V~ 32A 60Hz J2 - J3 J4 - J5 J6 - J7	③ - L1 BLACK ② - L2 RED ① - G GREEN	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1-HI / 3-L1-LO 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-L2 / 1-G	2-L1 1-L2	J15-L1 J16-L2	12V \square 1A or 5V \square 2A
		240V~ 10.5A	240V~ 3.5A	240V~ 10.5A	240V~ 10.5A	240V~ 1A	240V~ 10.5A	240V~	




240V~ and 120V~ 32A 60Hz J1 - J3 J4 - J5 J6 - J7

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)	CN1					
240V~ and 120V~ 32A 60Hz	TB1	CN1	CN3	CN1	CN2	CN4	CN10	J15 J16	CN22	
J1 - J3 J4 - J5 J6 - J7	④ - N WHITE ③ - L1 BLACK ② - L2 RED ① - G GREEN	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-N / 1-G	N/A	4-L1 / 3(N/A) 2-L2 / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-L2	J15-L1 J16-L2	12V \equiv 1A or 5V \equiv 2A	
		240V~ 10.5A	120V~ 3.5A		240V~ 10.5A	120V~ 1A	240V~ 10.5A	240V~		

Load carried by N line: CIRC PUMP / OZONE

Load carried by L2 line: PUMP1 / BLOWER / AUX / HEATER




240V~ and 120V~ 32A 60Hz **J2 - J3 J1 - J5 J6 - J7**

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)						
	TB1	CN1	CN3	CN1	CN2	CN4	CN10	J15 J16	CN22	
240V~ and 120V~ 32A 60Hz	J2 - J3 J1 - J5 J6 - J7	④ - L2 RED ③ - L1 BLACK ② - N WHITE ① - G GREEN	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1-HI / 3-L1-LO 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	4-L1 / 3(N/A) 2-N / 1-G	2-L1 1-N	J15-L1 J16-L2	12V \equiv 1A or 5V \equiv 2A
			120V~ 10.5A	120V~ 3.5A	120V~ 10.5A	120V~ 1A	120V~ 10.5A	240V~		


Load carried by N line: PUMP1 / CIRC PUMP / BLOWER / OZONE / AUX

Load carried by L2 line: HEATER



120V~ 32A 60Hz **J2 - J3 J4 - J5 J6 - J7**

CONNECTOR POWER TYPE	POWER INPUT	PUMP1(1 SPEED)*4		PUMP1(2 SPEED)*4		BLOWER (PUMP2)	OZONE	AUX	HEATER	LIGHT
		PUMP1(1 SPD)	CIRC PUMP (HEATER PUMP)	PUMP1 (HEATER PUMP)						
		TB1	CN1	CN3	CN1					
120V~ 32A 60Hz J2 - J3 J4 - J5 J6 - J7	③ - L BLACK ② - N WHITE ① - G GREEN	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L-HI / 3-L-LO 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	4-L / 3(N/A) 2-N / 1-G	2-L 1-N	J15-L J16-N	12V \equiv 1A or 5V \equiv 2A	
		120V~ 10.5A	120V~ 3.5A	120V~ 10.5A	120V~ 10.5A	120V~ 1A	120V~ 10.5A	120V~		




3.3. Configure load

There are two ways to configure the load: Use the Dip switch or use the control panel.

3.3.1. Use the Dip switch to configure the load

Use the Dip switch for load configuration: set the Dip switch positions A1-A6 according to the Dip switch S1 configuration table on the control system PCB




A1	<ul style="list-style-type: none"> ▲ HOST SYS: When there is only one SPA control pack, please set this pack as the main control system. ▼ SLAVE SYS: When set as a slave control system, it can form a multi-pack SPA control system with the main control system.
A2	<ul style="list-style-type: none"> ▲ POWER NOT LIMIT ▼ POWER LIMIT: If the water pump 1,2 is turned on at high speed, the thermostat will turn off.
A3	<ul style="list-style-type: none"> ▲ BLOWER OUTPUT: CN2 output blower function ▼ PUMP2 OUTPUT: CN2 output pump 2 function
A4	<ul style="list-style-type: none"> ▲ SETTING ▼ STORE SETTING
A5	<ul style="list-style-type: none"> ▲ PUMP1 1 SPEED ▼ PUMP1 2 SPEED
A6	<ul style="list-style-type: none"> ▲ REF A3 ▼ CN2 AUX POWER: CN2 output auxiliary power function

3.3.2. Configure functions using the control panel. Panels: PB562 Plus control panel/PB563 Plus control panel/PB565 Plus control panel.

(1) Use the control panel PB562 Plus for functional configuration.

Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 1: Connect the PB562 control panel to the P68B123 control system.

Step 2: Turn the Dip switch A4 to ON.


Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.




Step 3: Power ON, the PB562 control panel will automatically turn on, and then operate on the PB562 control panel.



Step 4: Press the button " " to enter the Settings interface.



Step 5: Press the button " " " " to select Information, and then press the button " " to enter the Information interface.




Step 6: Press and hold the button " " for about 3 seconds to enter the Function interface and set the load.

(Simple method to change the light type: After powering off the SPA for one minute, re-power it on. Within 5 minutes, enter Information interface, press and hold " " for 8 seconds, and switch between RGB and ON/OFF modes)

Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.

Press the "  " or "  " buttons to select the item that needs to be changed, and then press the button "  " to make the change.





 RGB : The lights connected to the control system are of RGB type

 ON/OFF: The lights connected to the control system are of ON/OFF type

After configuration is completed, press "  " to return to the Settings interface.

Step 7: Select the function you want to set.




Step 8: Power OFF.

Step 9: Dial to Off to complete the configuration.

(2) Function configuration using PB563 Plus control panel


Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 1: Connect the PB563 control panel to the P68B123 control system.

Step 2: Turn the Dip switch A4 to ON.


Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 3: Power ON, the PB563 control panel will automatically turn on, and then operate on the PB563 control panel.



Step 4: Press the button "  " to activate the function menu, press the buttons "  " "  " "  " "  " to switch to the icon "  " , and then press the button "  " to enter the Settings interface.



Step 5: Press the button "  " "  " to select Information, and then press the button "  " to enter the Information interface.



Step 6: Press and hold the button "  " for about 3 seconds to enter the Function interface and set the load.
(Simple method to change the light type: After powering off the SPA for one minute, re-power it on. Within 5 minutes, enter Information interface, press and hold "  " for 8 seconds, and switch between RGB and ON/OFF modes)

Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Use the " " or " " buttons to select the item that needs to be changed, and then press the button " " to make the change.



It cannot be configured here (Dip switch setting is required, reference 3.3.1)

Press " " to switch between 1 Speed or None

Press " " to switch between 1 Speed or None

Press " " to switch between 1 Speed or None

Press " " to switch between RGB or ON/OFF

Press " " to switch between YES or None



Press " " to switch between YES or None

RGB : The lights connected to the control system are of RGB type

ON/OFF: The lights connected to the control system are of ON/OFF type

After configuration is completed, press " " to return to the Settings interface.

Step 7: Select the function you want to set.




Step 8: Power OFF.

Step 9: Dial to Off to complete the configuration.

(3) Function configuration using PB565 Plus control panel

Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 1: Connect the PB565 control panel to the P68B123 control system.

Step 2: Turn the Dip switch A4 to ON.


Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 3: Power ON, the PB565 control panel will automatically turn on, and then switch to the PB565 control panel for operation.



Step 4: Find the " " icon in the menu interface and press the icon to enter the Settings interface.




Step 5: Find Information on the Settings interface, press and hold About for about 3 seconds to enter the Function interface to set the load




(Simple method to change the light type: After powering off the SPA for one minute, re-power it on. Within 5 minutes, enter Information interface, press and hold "Light" for 8 seconds, and switch between RGB and ON/OFF modes)

Note: The operation of configuring functions using the control panel must be completed within 60 seconds after the control system being powered on.



Step 6: Select the function you want to set.




Step 7: Power OFF.

Step 8: Dial to Off to complete the configuration.

3.3.3、Power configuration of the lamp

The power configuration of the lamp is set according to the S2 configuration table on the PCB board of the control system.



- ▲ 12V □ : When set up ▲, the power output of the lamp is 12V
- ▼ 5V □ : When set down ▼, the power output of the lamp is 5V


4、Replaceable parts

Heating tube: 2KW heating tube
3KW heating tube
4KW heating tube

Fuse: Current Position number
10A F3


PB562/PB562 Plus control panel

2.4 inch TFT color display screen, 8 capacitive touch buttons.




PB563/PB563 Plus control panel control panel

3.5 inch TFT color display screen, 10 capacitive touch buttons



PB565/PB565 Plus control panel control panel

5.0 inch TFT color display screen, screen touch operation





Sun Hydraulics (China) Co.,Ltd. Dongguan Branch
ADD: Room 302, Building 10, 38 Dongke Road, Dongcheng Street
Dongguan city, Guangdong Province
TEL: +86 (755) 26010708
Sales Tel: +86 (755) 26010859
Oversea sales: (+86) 13925211653
China sales: (+86) 13602626203
PC.: 523749
WEB: www.joyonway.com
After-sales service: service@joyonway.com